**ON Semiconductor** 

Is Now

# Onsemi

To learn more about onsemi<sup>™</sup>, please visit our website at <u>www.onsemi.com</u>

onsemi and ONSEMI. and other names, marks, and brands are registered and/or common law trademarks of Semiconductor Components Industries, LLC dba "onsemi" or its affiliates and/or subsidiaries in the United States and/or other countries. onsemi owns the rights to a number of patents, trademarks, copyrights, trade secrets, and other intellectual property. A listing of onsemi product/patent coverage may be accessed at www.onsemi.com/site/pdf/Patent-Marking.pdf. onsemi reserves the right to make changes at any time to any products or information herein, without notice. The information herein is provided "as-is" and onsemi makes no warranty, representation or guarantee regarding the accuracy of the information, product factures, availability, functionality, or suitability of its products for any particular purpose, nor does onsemi assume any liability arising out of the application or use of any product or circuit, and specifically disclaims any and all liability, including without limitation special, consequential or incidental damages. Buyer is responsible for its products and applications using onsemi products, including compliance with all laws, regulations and asfety requirements or standards, regardless of any support or applications information provided by onsemi. "Typical" parameters which may be provided in onsemi data sheets and/or by customer's technical experts. onsemi products and actal performance may vary over time. All operating parameters, including "Typicals" must be validated for each customer application by customer's technical experts. onsemi products are not designed, intended, or authorized for use as a critical component in life support systems or any FDA Class 3 medical devices or medical devices with a same or similar classification in a foreign jurisdiction or any devices intended for implantation in the human body. Should Buyer purchase or use onsemi products for any such unintended or unauthorized application, Buyer shall indemnify and hold onsemi and its officers, employees, subsidiari

# TND6115/D

# Image Sensor ISO Measurement

## **ISO Measurement**

There are many ways to describe the sensitivity of an imaging system to light. It is traditional for the sensitivity of a digital image sensor to be specified in terms of its quantum efficiency – the number of electrons generated for each incident photon. It is also common to measure responsivity, or the output in volts generated during an exposure ( $\mu$ J/cm<sup>2</sup>). In some cases the exposure is defined in photometric units (lux × seconds).

Traditionally, film sensitivity has been specified in terms of speed or "ISO". ISO gives the exposure index at which specified image quality parameters are achieved. Exposure index is given by:

$$\mathsf{EI} = \frac{10}{\mathsf{H}} \tag{eq. 1}$$

where 'H' is the exposure in  $lux \times s$ .

Because it is often useful to compare digital imaging systems to conventional silver-halide based photographic systems, standards have been developed that allow the measurement of ISO for digital imaging systems. Using a particular ISO speed value as the exposure index on an electronic still camera should result in the same focal plane exposure as would be obtained using that exposure index on a film camera.

There are two basic types of ISO: saturation-based and noise-based. The saturation-based ISO is also referred to as the 'base ISO'. The type of ISO of interest depends on the application at hand. In applications where the lighting conditions are controlled, like studio photography, exposure index settings are selected to give the best possible image, with the image highlights falling just below the saturation level. This exposure situation is described by the saturation-based ISO.

When lower than ideal lighting conditions are expected, a noise–based ISO is more useful. In this calculation the signal to noise ratio (SNR) that gives a reasonable image for the application of interest is used to calculate the ISO. This ISO corresponds to the maximum EI setting to achieve that SNR. It is common in photography to designate SNR = 40 as an 'excellent image' and SNR = 10 as an 'acceptable image' and calculate a corresponding noise-based ISO for each.

The ISO of ON Semiconductor image sensors is determined through direct measurement and application of the following formula:

$$ISO = \frac{15.4 \times f\#^2}{L \times t}$$
 (eq. 2)



## **ON Semiconductor®**

http://onsemi.com

# **TECHNICAL NOTE**

where 'ISO' represents the base or saturation-based ISO, 'f#' is the effective f number of the camera lens used in the measurement, 'L' is the luminance of an 18% reflector in the scene (cd/m<sup>2</sup>) and 't' is the length of the exposure in seconds.

The choice of an 18% reflector is somewhat arbitrary, but generally an 18% gray patch is available in the laboratory so this is a convenient choice. The constant in the front is determined by making some assumptions about a typical imaging system – 90% lens transmission, a vignetting factor of 0.98, and an image point that is 10° off axis, which folds into the  $\cos^4 \theta$  part of the calculation of the actual exposure on the image plane.

To measure the scene luminance, the lighting is varied until the camera outputs an average value equal to 18/106 of full scale when imaging the 18% reflecting surface. During this adjustment the exposure time is held constant. Full scale is either where the imager saturates or where the camera's ADC reaches its maximum value, whichever happens first.

The use of the number 106 is not arbitrary – it means that we want to accommodate a reflectance of up to 106% for image highlights. Very demanding applications might need more headroom for highlights, and so might use a higher number when calculating base ISO.

The scene luminance is measured with a light meter in  $cd/m^2$  and entered into the equation with the f number and integration time. For a color imaging system, the ISO measurement is performed on the highest speed channel – green for an RGB imager.

This measurement depends on just about everything – lenses, IR cut filters, camera gain and offset settings, mapping of the output voltage to the ADC, just to name a few. So take care that the camera system is set up exactly as it will be used in the end application.

The KAF-16801 Image Sensor, a 16 megapixel full-frame CCD image sensor with 9 micron pixels, a Red–Green–Blue color filter array, and no microlenses has a base ISO just over 100 assuming a demanding 170% reflectance tolerance for highlights or base ISO around 62 assuming 106%. This ISO is more than adequate for the studio lighting conditions under which this sensor is typically used.

Semiconductor Components Industries, LLC, 2014 July, 2014 – Rev. 2

### Reference

International Organization for Standardization standard 12232, Photography – Electronic Still Picture Cameras – Determination of ISO Speed. (See International Organization for Standardization, www.iso.ch)

ON Semiconductor and the use are registered trademarks of Semiconductor Components Industries, LLC (SCILLC) or its subsidiaries in the United States and/or other countries. SCILLC owns the rights to a number of patents, trademarks, copyrights, trade secrets, and other intellectual property. A listing of SCILLC's product/patent coverage may be accessed at www.onsemi.com/site/pdf/Patent-Marking.pdf. SCILLC reserves the right to make changes without further notice to any products herein. SCILLC makes no warranty, representation or guarantee regarding the suitability of its products for any particular purpose, nor does SCILLC assume any liability arising out of the application or use of any product or circuit, and specifically disclaims any and all liability, including without limitation special, consequential or incidental damages. "Typical" parameters which may be provided in SCILLC data sheets and/or specifications can and do vary in different applications and actual performance may vary over time. All operating parameters, including "Typicals" must be validated for each customer application by customer's technical experts. SCILLC does not convey any license under its patent rights nor the rights of others. SCILLC products are not designed, intended, or authorized for use as components in systems intended for surgical implant into the body, or other applications intended to support or sustain life, or for any such unintended or unauthorized application. Buyer shall indemnify and hold SCILLC and its officers, employees, subsidiaries, affiliates, and distributors harmless against all claims, costs, damages, and expenses, and reasonable attorney fees arising out of, directly or indirectly, any claim of personal injury or death associated with such unintended or unauthorized use, even if such claim associated with such unintended or unauthorized use, even if such claim application is personal injury or death may occur. Should Buyer purchase or use SCILLC products for any such unintended or unauthorized application,

#### PUBLICATION ORDERING INFORMATION

#### LITERATURE FULFILLMENT:

Literature Distribution Center for ON Semiconductor P.O. Box 5163, Denver, Colorado 80217 USA Phone: 303-675-2175 or 800-344-3860 Toll Free USA/Canada Fax: 303-675-2176 or 800-344-3867 Toll Free USA/Canada Email: orderlit@onsemi.com N. American Technical Support: 800–282–9855 Toll Free USA/Canada Europe, Middle East and Africa Technical Support:

Phone: 421 33 790 2910 Japan Customer Focus Center Phone: 81-3-5817-1050 ON Semiconductor Website: www.onsemi.com

Order Literature: http://www.onsemi.com/orderlit

For additional information, please contact your local Sales Representative